



1 November 2019

Proposed Plan Change 6 (Further Submissions)
City Planning Unit
Hamilton City Council
Private Bag 3010
HAMILTON 3240

By email: districtplan@hcc.govt.nz

Dear Sir/Madam,

FURTHER SUBMISSION ON HAMILTON CITY COUNCIL'S PROPOSED PLAN CHANGE 6

Please find attached to this letter a further submission by WEL Networks Limited on proposed Plan Change 6.

WEL wishes to be heard in support of its submission (reference 22), and this further submission. If others make a similar submission, WEL would consider presenting a joint case at the hearing.

Please contact me for any matter related to this further submission.

Yours sincerely,

A handwritten signature in black ink, appearing to read 'KL Broughton'.

Karleen Broughton
COMMERCIAL LEGAL COUNSEL

E-mail: karleen.broughton@wel.co.nz
DDI: 850 3645



Further Submission by WEL Networks Limited on Proposed Plan Change 6

Submission Reference	Name of Submitter	Support or Oppose	Reason for WEL Support or Oppose	Decision Requested
14.14	Peter Findlay	Oppose	<p>This submission seeks to delete Rule 25.2.4.1(g) which seeks to ensure that <i>earthworks must not cause malfunction or result in damage to network utilities, or change the cover over network utilities so as to create the potential for damage or malfunction.</i></p> <p>WEL opposes this submission as the proposed rule, subject to WEL's requested amendments, seeks to control earthworks in the vicinity of utilities which have the potential to damage network equipment.</p>	Amend Rule 25.2.4.1(g), subject to the amendments in WEL's submission (reference 22.02).
16.02	Transpower NZ	Support in Part	<p>This submission seeks to retain Rule 25.2.4.1(g).</p> <p>WEL supports this submission in part subject to the amendments in WEL's original submission (reference 22.02).</p> <p>The additional wording requested by WEL's submission will ensure that any developer/contractor is aware of the technical standards. For example earthworks within proximity to network equipment must also comply with the requirements of the New Zealand Electrical Code of Practice for Electrical Safe Distances (NZECP34).</p>	Amend Rule 25.2.4.1(g), subject to the amendments in WEL's submission (reference 22.02).

