



### NOTES

1. The detail on this drawing is typical only.
2. Pump Station offset is measured from the driveway centreline to the centreline of the furthest pump.
3. Area around pump station shall be graded to prevent surface water flowing onto or over pump station cover slabs.
4. Landscaping may be required dependent upon site location and area available.
5. Full fencing is not required if the pump station is located within a reserve and bollards may be used of a design approved by HCC. Otherwise if pump station is located next to residential property, a 1.8m high close boarded timber fence is to be constructed.