


FRAME FOR DOUBLE LID
(3085 & 3102 Pumps)



DOUBLE LID
(3085 & 3102 Pumps)

NOTES

1. All dimensions in mm.
2. Refer to Drawings TS 526 and TS 527 for frame details and TS 528 for lid details.
3. All welds to be continuous.
4. Frames to be 316 Stainless Steel.
5. Lids to be 6mm aluminium checker plate.
6. Lids and frames to be matched set.
7. Grouting lugs to be welded to frame 100mm in from each corner as shown in plan view - Refer to Detail TS 528.