



NOTES:

1. 2 or more gate valves to be situated in a meter box.
2. Connections from rider mains to be made using 63 x 63 mdPE tee in place of a tapping band or tapped gibault. Tee to be placed horizontally to maintain standard cover.
3. This arrangement of manifold and separate supply pipes is suitable for up to 4 dwellings. For 5 or more dwellings a rider main configuration shall be used.