



- NOTES:**
1. The Designer shall submit details of the proposed installation to Water, Drainage and Refuse Unit for approval.
 2. Should space permit (e.g. behind boundary) a 1200mm manhole chamber shall be used.
 3. Protective membrane to be wrapped around pipe where it passes through chamber wall (2.5mm Polythene)
 4. 2 Flexible joints to be provided within 2m of chamber.
 5. Protective wrapping to CLSS pipe to be made good after welding.
 6. To generate sufficient earth friction on pipe, a minimum of 6m of pipe to be laid between meter and sluice valves.

STANDARD METER PIT FOR 100 & 150mm METERS