

Sarah Blanchett

From: Mark Vinall <mark.vinall@tattico.co.nz>
Sent: Tuesday, 10 September 2019 08:00
To: Andrew Cumberpatch
Cc: Ross Cooper
Subject: RE: Proposed acoustic conditions

Importance: High

Hi Andrew,

I can confirm that you can remove the Building Damage Classification table, the other conditions are to remain.

Kind regards,

Mark

Tattico Limited
Mobile: 027 280 8281

From: Andrew Cumberpatch [mailto:Andrew.Cumberpatch@boffamiskell.co.nz]
Sent: Monday, 9 September 2019 10:54 AM
To: Mark Vinall <mark.vinall@tattico.co.nz>
Cc: Ross Cooper <ross.cooper@tattico.co.nz>
Subject: RE: Proposed acoustic conditions

Hi Mark

Thank you for forwarding these on.

Can you please confirm asap what approach is now with the following in "Draft Conditions v4.docx":

- The Building Damage Classification (Table 1)
- Conditions 20, 76 and 81 (Building condition surveys)

Kind regards
Andrew

From: Mark Vinall <mark.vinall@tattico.co.nz>
Sent: Monday, 9 September 2019 10:19 AM
To: Andrew Cumberpatch <Andrew.Cumberpatch@boffamiskell.co.nz>
Cc: Ross Cooper <ross.cooper@tattico.co.nz>
Subject: Proposed acoustic conditions
Importance: High

Good morning Andrew,

We have engaged Marshall Day to review the draft acoustic conditions included in our proposed draft conditions of consent sent to you.

With respect to the construction noise and vibration conditions, in lieu of Conditions 34 through 38 in "Draft Conditions v4.docx" we propose the following amended conditions:


34. Construction works shall be measured and assessed in accordance with the provisions of NZS 6803:1999, and comply, as far as practicable, with the relevant noise levels stated in NZS6803: 1999, section 7.2 'Recommended numerical limits for construction noise'
35. Construction vibration shall comply with the limits in Table 1 and Table 3 of DIN 4150-3:1999 "*Structural vibration – Part 3: Effects of vibration on structures*".
36. At least 10 days prior to Commencement of Construction, the Consent Holder shall prepare a Construction Noise and Vibration Management Plan ("CNVMP") and submit it to the Council (Team Leader Compliance Monitoring) for certification that the CNVMP gives effect to the objectives and complies with the requirements in Conditions 34 and 35.
37. The objectives of the CNVMP are:
 - a) Identify and adopt the Best Practicable Option for the management of construction noise and vibration;
 - b) Define the procedures to be followed when construction activities cannot meet the noise and vibration standards in Conditions 34 and 35;
 - c) Inform the duration, frequency and timing of works to manage disruption; and
 - d) Require engagement with affected receivers and timely management of complaints.
38. The CNVMP shall include:
 - a) The relevant measures from NZS 6803:1999 "Acoustics - Construction Noise", Annex E2 "Noise management plans";
 - b) The relevant measures from DIN 4150-3:1999 "Structural vibration - Part 3 Effects of vibration on structures", Appendix B "Measures for limiting the effects of vibration"

Please contact me if you require anything further.

Kind regards

Mark Vinall | Director | Tattico Limited
Level 10, West Plaza Tower, 1-3 Albert Street,
Auckland 1010
PO Box 91562, Victoria Street, Auckland 1142, New
Zealand
www.tattico.co.nz

mobile. +64 27 280 8281
phone. +64 9 973 4282

tattico 

This email contains confidential information and may be legally privileged. The information transmitted is for the use of the intended recipient only. Any review, re-transmission, disclosure or dissemination of this material by persons other than the intended recipient is prohibited. While we use standard virus checking software, we accept no responsibility for viruses or anything similar in this email or any attachment after it leaves our information systems.

This email contains confidential information and may be legally privileged. The information transmitted is for the use of the intended recipient only. Any review, re-transmission, disclosure or dissemination of this material by persons other than the intended recipient is prohibited. While we use standard virus checking software, we accept

no responsibility for viruses or anything similar in this email or any attachment after it leaves our information systems.

This electronic message together with any attachments is confidential. If you receive it in error: (i) you must not use, disclose, copy or retain it; (ii) please contact the sender immediately by reply email and then delete the emails. Views expressed in this email may not be those of Boffa Miskell Ltd. No claim may be made against Boffa Miskell in regard to the use of data in any attachments. This e-mail message has been scanned for Viruses and Content.

This email contains confidential information and may be legally privileged. The information transmitted is for the use of the intended recipient only. Any review, re-transmission, disclosure or dissemination of this material by persons other than the intended recipient is prohibited. While we use standard virus checking software, we accept no responsibility for viruses or anything similar in this email or any attachment after it leaves our information systems.

This email contains confidential information and may be legally privileged. The information transmitted is for the use of the intended recipient only. Any review, re-transmission, disclosure or dissemination of this material by persons other than the intended recipient is prohibited. While we use standard virus checking software, we accept no responsibility for viruses or anything similar in this email or any attachment after it leaves our information systems.